

Heat Pump Equipment and Central Air Conditioners Key Product Criteria

Product Type	Specification
Heat Pump Equipment (HP)	≥ 7.8 HSPF2/ ≥15.2 SEER2/ ≥11.7 EER2 for split systems ≥ 7.2 HSPF2 ≥15.2 SEER2/ ≥10.6 EER2 for single package equipment including gas/electric package units.
Central Air Conditioners (CAC)	≥15.2 SEER2/ ≥12.0 EER2 for split systems ≥15.2 SEER2/ ≥11.5 EER2 for single package equipment including gas/electric package units.